



Ref.: CMPDI/RI-1/E&amp;M/2017/169

Date: 08-May-2017

**TENDER NOTICE****SUB. : REWIRING & MODIFICATION OF QR. NO. 6 (D-type), 4B & 7A (C-type) IN CMPDI, RI-I, ASANSOL**

Sealed tenders are invited from Authorized Agents / Authorized Dealer / Bonafide / Working / Reputed Supplier / Contractors (of appropriate category) for supply & installation of "**REWIRING & MODIFICATION OF QR. NO. 6 (D-type), 4B & 7A (C-type) IN CMPDI, RI-I, ASANSOL**" as per SCHEDULE OF REQUIREMENT / TECHNICAL SPECIFICATION (ANNEXURE-I) and TERMS & CONDITIONS given below :

a) Tender fee : Not applicable

b) Earnest Money : ₹1,319/- (Rupees one thousand three hundred nineteen only)

c) Date of Commencement of sale of Tender Documents : **08-May-17 (from 10.30 AM to 12.00 Noon)**

d) Last date of sale of Tender Documents : **18-May-17 up to 12.00 Noon**

e) Last date & time for submission of offers : **19-May-17 up to 01:00 PM**

f) Due date & time of opening of Offers : **19-May-17 at 03.30 PM**

g) Validity Period : Six months from the date acceptance of offer

h) Type of Tender : Single Bid

**IF THE TENDER IS NOT OPENED ON THE ABOVE DATE DUE TO UNFORESEEN CIRCUMSTANCES, THEN IT WILL BE OPENED ON THE NEXT WORKING DATE. TENDERER OR THEIR AUTHORIZED REPRESENTATIVES MAY ATTEND THE OPENING OF THE TENDER. AUTHORISED REPRESENTATIVE MUST PRODUCE A POWER OF ATTORNEY IN HIS FAVOUR.**

Tender document can be obtained from the office of **DY. GM (E&M)/HOD**, CMPDI, RI-1, Asansol during **10.30 AM to 12.00 Noon** on all working days from **8-May-17 to 18-May-17**. Tender documents can also be downloaded from CMPDI'S website [www.cmpdi.co.in](http://www.cmpdi.co.in) & Government website [www.tender.gov.in](http://www.tender.gov.in) during the period from **08-May-17 to 18-May-17**. Bidders shall be solely responsible for the correctness of the downloaded tender documents.

In case of any discrepancy between the tender documents downloaded from the website and the master copy available in the office, the latter shall prevail and will be binding on the bidders. **No claim on this account will be entertained.**

Tender must be submitted in sealed covers super-scribed with the Tender Number and due date of opening, time etc.

Tenderer shall furnish their offer along with the EMD in sealed cover addressed to the **Dy. GM (E&M)/HOD**. The offers should be dropped in the designated '**TENDER BOX**' kept in the Office of **Dy.GM (E&M)/HOD**, RI-1, CMPDI, Asansol.

#### **Dy. GM (E&M)/HOD**

#### **DISTRIBUTION:-**

1. RD, RI-1, Asansol.
2. Committee Member, RI-1, Asansol.
3. GM (Fin), RI-1, Asansol.
4. OIC (P&A), CMPDI, RI-1, Asansol, with a request to arrange for display in the NOTICE BOARD
5. CGM (E&M), ECL, Sanctoria with a request to arrange for display in the NOTICE BOARD.
6. Exec. Engr., PWD, Court Road, Asansol with a request to arrange for display in the NOTICE BOARD.
7. Manager, UBI, Apcar Garden, Asansol with a request to arrange for display in the NOTICE BOARD.
8. Asst. General Manager, SBI, Asansol with a request to arrange for display in the NOTICE BOARD.
9. Exec. Engr., PHE, Chelidanga, Asansol with a request to arrange for display in the NOTICE BOARD.
10. Office Copy
11. Guard File

#### **TERMS & CONDITIONS:**

##### **1. MODE & METHOD OF SUBMISSION OF TENDER**

Tender must be submitted in sealed covers super-scribed with the Tender Number and due date of opening, time etc.

2. Tenderer shall furnish their offer along with the EMD in sealed cover addressed to the Dy.GM (E&M)/HOD. The offers should be dropped in the designated 'TENDER BOX' kept in the Office of **DY.GM (E&M)/HOD, RI-I, CMPDI, Asansol.**
3. Supporting Brochure of the Models offered for all the items conforming to all the technical details should be submitted along with the offer.
4. The offer shall be accompanied with the copies of :-
  - a) Valid Trade license
  - b) VAT Registration Certificate
  - c) PAN No.
  - d) Elect. Supervisor license
  - e) Workman's license
  - f) Credentials for similar nature of work with supporting documents

#### 5. **NOTE**

- a. **ALL PAGES OF THE OFFER ALONG WITH THE ENCLOSURES ARE TO BE SUBMITTED DULY SIGNED AND STAMPED.**
- b. **TENDERS ERASED, CUTTING AND OVER WRITTEN WILL BE SUMMARILY REJECTED UNLESS CORRECTION IS AUTHENTICATED WITH THE TENDERER'S SIGNATURE.**

6. Bidders may visit the work site before quoting the rates.
7. The work shall be supervised by qualified Engineers.
8. **PAYMENT OF EMD**

EMD should be in the form of Bank Draft. Bank Draft should be drawn in favour of CMPDI LTD., Regional Institute, Asansol on any scheduled bank payable at Asansol preferably on "State Bank of India".

In case Earnest Money is not submitted, the offer shall be out-rightly rejected without any reference on this subject. EMD shall be refunded to the unsuccessful tenderer on request and on production of original money receipt immediately after finalization and award of the tender. For successful tenderer EMD will be converted to Security Money which will be refunded to the firm on certification after completion of one year of Guarantee / Warranty Period from final inspection, after installation of the system at site. The deposits like Earnest Money will not carry any interest during its period of retention.

#### **The deposits like Earnest money may be forfeited:**

- If any tenderer withdraws their offer after tender opening during the period of tender validity.
- If the tenderer fails to execute the order job after acceptance of order within the specified time limit or does not fulfill any of the terms & conditions.

**9. VALIDITY OF OFFER**

The offers made must remain open for acceptance for 180 days from the date of opening of tender.

**10. CONSIGNEE**

The Regional Director, CMPDI, RI-1, Asansol – 713 304.

**11. PAYING AUTHORITY**

HOD (F), CMPDI, RI-1, Asansol.

**12. PRICE**

The rate shall be quoted both in words and in figures on FOR-destination basis. **If there is any discrepancy between the rates quoted in words and in figures, the lower of the two shall be considered.** The offer should indicate rate per unit, discount, if any, total price and delivery terms. The rates should be inclusive of all applicable taxes and duties.

**13. SECURITY DEPOSIT**

- (a) The successful tenderers will be required to deposit as security money **5%** of total value of the order (FOR destination price including taxes and duties) in the form of Demand Draft / Bank Guarantee of any schedule Bank payable at Asansol preferably on **State Bank of India** within 15 days from the date of issue of the supply order. For successful bidder Earnest Money will be adjusted against the total security money of **5%** of the value of the order to be placed.
- (b) In case tenderer fails to deposit Security Money within the stipulated period the order shall be cancelled and EMD deposited against this tender shall be forfeited. Simultaneous action will be processed to order elsewhere at the risk and cost of the tenderer and their performance shall be kept in record for future dealings.

The Security Deposit will be forfeited in case of unsatisfactory performance and / or contractual failure. Security money / Bank Guarantee of the eligible bidders will be released on certification after expiry of **one year /Guarantee / Warranty Period** whichever is earlier. The deposits like security money etc. will not carry any interest during its period of retention.

**14. PAYMENT TERM**

- a) **Payment of the billed amount after deducting retention money (i. e. 5% of bill amount as security deposit) shall be made after successful completion of job at site. The payment would be on the basis of actual work done.**

**15. SUBMISSION OF BILL**

Pre-receipted bill in triplicate along with signed challan, Guarantee / Warranty Certificate & installation report are to be submitted to the concerned department. Payment shall be released on certified bills by the concerned authority.

## 16. COMPLETION

The job shall have to be completed within **45 (Forty-five)** days from the date of receipt of the order.

## 17. INSPECTION

Materials are subject to inspection by an authority to be deputed for the purpose at Consignee's end. It may be carried out before dispatch, if required. Even after pre-dispatch inspection is carried out the materials will be subjected to final inspection & receipt of the materials at site.

## 18. GUARANTEE / WARRANTY

The Tenderer shall give comprehensive onsite Guarantee / Warranty of satisfactory performance of equipment offered by them for a period of **1 year** w.e.f. date of installation & commissioning. In case of other items, Standard **OEM** Warranty should be indicated. The Guarantee / Warranty period will be extended by the number of days the replacement / repairing was delayed.

The supplier shall be responsible for any defects that they develop under the conditions provided for by the contract and proper use, arising from faulty materials, design or workmanship and shall remedy such defects his own cost when called upon to do so. If it became necessary for the supplier to replace or renew any defective portion of the goods, such replacement or renewal should be made by the supplier without any extra cost of CMPDI.

## 19. FORCE MAJEURE CLAUSE

- a) The successful bidder will advise, in the event of his having to resort to this clause, by a registered letter, duly certified by the local chamber of commerce, or statutory authorities, the beginning and end of the causes of the delay, within 15 days of the occurrence and cession of such force majeure conditions. In the event of delay lasting out of force majeure, CMPDI will reserve the right to cancel the contract, and provisions governing termination of contract as stated in the bid documents will apply.
- b) For delay arising out of Force majeure, the bidder will not claim the extension in completion date for a period exceeding the period of delay attributable to the causes of force majeure and neither CMPDI nor the bidder shall be liable to pay extra cost provided it is mutually established that the force majeure conditions did actually exist.
- c) If any of the force majeure conditions exist in the place of operation of bidder even in the time of submission of bid, he will categorically specify them in his bid, and state whether they have been taken in to consideration in their quotation.
- d)

## 20. DEVIATION

Any willful attempt by the bidders to camouflage the deviations by giving them in the covering letter or in any other documents other than the prescribed schedules may render the bid itself non responsive.

21. The Company has the right to cancel the enquiry or extend the due date of receipt of offer and/or opening of tender without assigning any reason thereof.
22. CMPDI, RI-1 reserves the right to accept or reject fully or partly or split-up any or all offers without assigning any reason thereof. No disputes of any kind can be raised against this right of the buyer in any court of law or elsewhere. **NO CORRESPONDENCES WILL BE ENTERTAINED IN THIS REGARD.**
23. **ALL DISPUTES ARE SUBJECT TO ASANSOL COURT JURISDICTION ONLY.**

Encl:

- a) ANNEXURE – I (SCHEDULE OF REQUIREMENT / TECHNICAL SPECIFICATION )
- b) ANNEXURE -II (Proforma of Bank Guarantee in lieu of Part Bid Security/EMD)

## ANEXXURE - I

## SCHEDULE OF REQUIREMENT / TECHNICAL SPECIFICATION :

<b>"A" Rewiring &amp; modification of power supply arrangement of Qr. No. 6(D-Type)</b>						
<b>q</b>	<b>Reference</b>	<b>Description</b>	<b>Qty.</b>	<b>Unit</b>	<b>Unit Cost (₹)</b>	<b>Total Cost (₹)</b>
1	CPWD DSR (Elect.) -2012, Code-1.10 (P-2)	Wiring for light point / fan point / exhaust fan point / call bell point with <b>1.5 sq. mm</b> FR PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with <b>1.5 sq. mm</b> . FR PVC insulated copper conductor single core cable etc as required.				
1.1	1.10.3	Group C	33	Point		
2	CPWD DSR (Elect.) -2012, Code-1402 (P-49)	SP 5/6 amps, one way modular switch, ISI marked	10	Each		
3	CPWD DSR (Elect.) -2012, Code-1404 (P-49)	SP 15/16 amps, one way modular switch, ISI marked	6	Each		
4	CPWD DSR (Elect.) -2012, Code-1405 (P-49)	3 pin 5/6 amps modular socket outlet, ISI marked	10	Each		
5	CPWD DSR (Elect.) -2012, Code-1406 (P-49)	6 pin 15/16 amps modular socket outlet, ISI marked	6	Each		
6	CPWD-DSR (Elect.)-2012, Code - 1.25 (Page - 7)	Supplying & fixing stepped type electronic fan regulator on existing modular plate (switch box including connections but excluding modular plate) etc. as required.	5	Each		

7	CPWD,DSR (Elect.-2012), 1.12, page -3	Wiring for light / power plug with 2X4 sq. mm. FR PVC insulated copper conductor single core cable in surface/ recessed medium class PVC conduit along 1 No. 4 sq. mm. FR PVC insulated copper conductor single core cable for loop earthing as required.	75	Metre		
8	Ref.- CPWD,DSR (Elect.-2012), 1.14, page -3	Wiring of circuit /submain wiring along with earth wire with the following size of FR PVC insulated copper conductor, single core cable in surface/recessed medium class PVC conduit as required				
8.1	1.14.2	2x2.5 sq.mm+1x2.5 sq.mm earth wire	60	Metre		
9	Ref.- CPWD,DSR (Elect.-2012), 1.27, page -7	Supplying and fixing following size/modules, GI box along with modular base & cover plate for modular switches in recess etc as required				
9.1	1.27.2	3 Module (100mmx75mm)	16	each		
10	Ref.- CPWD,DSR (Elect.-2012), 2.3, page -10	Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 volts on surface /recess, complete with tinned bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required.(But without MCB/RCCB/Isolator)				
10.1	2.3.8	2+12way, Double door	1	each		
11	CPWD SOR (Elect.) -2012, Code-2.10 (P-13)	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.				

11.1	2.10.1	Single pole (20 A - 6 No. + 10 A - 5 No.)	11	Each		
12	CPWD-SOR (Elect.)-2012, Code - 1.18 (Page - 5)	Supplying and drawing following pair 0.5 sq mm FR PVC insulated annealed copper conductor, unarmored telephone cable in the existing surface/ recessed steel/ PVC conduit as required.				
12.1	1.18.2	2 Pair	10	Each		
13	CPWD-DSR (Elect.)-2012, Code - 1.19 (Page - 5)	Supplying and drawing co-axial TV cable RG-6 grade, 0.7 mm solid copper conductor PE insulated, shielded with fine tinned copper braid and protected with PVC sheath in the existing surface/ recessed steel/ PVC conduit as required.	10	Each		
14	CPWD-DSR (Elect.)-2012, Code - 1410 (Page - 49 )	T.V. Socket outlet modular type	1	Each		
15	CPWD-DSR (Elect.)-2012, Code - 2.14 (Page - 13)	Supplying and fixing following rating, double pole, (single phase and neutral), 240 volts, residual current circuit breaker (RCCB), having a sensitivity current upto 300 milliamperes in the existing MCB DB complete with connections, testing and commissioning etc. as required.				
15.1	2.14.2	40 amps	1	Each		
16	CPWD-DSR (Elect.)-2012, Code - 1742 (Page - 55 )	Sheet steel DP MCB enclosure	1	Each		
17	CPWD-DSR (Elect.)-2012, Code - 2.12 (Page - 13)	Supplying and fixing following rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.				
17.1	2.12.1	40 amps	1	Each		

18	CPWD-DSR (Elect.)-2012, Code - 1.22 (Page - 6 )	Supplying and fixing metal box of following sizes (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in front including painting etc as required.				
18.1	1.22.2	100 mm X 100 mm X 60 mm deep	10	Each		
19	CPWD DSR (Elect.) -2012, Code- 1.50 (P-9)	Installation of exhaust fan in the existing opening, including making good the damage, connection, testing, commissioning etc. as required.				
19.1	1.50.1	Upto 450 mm sweep	1	Each		
Total "A"						Rs.
<b>"B" Rewiring &amp; modification of power supply arrangement of Qr. No. 4 /B (C-Type )</b>						
S/N	Reference	Description	Qty.	Unit	Unit Cost (₹)	Total Cost (₹)
1	CPWD DSR (Elect.) -2012, Code-1.8 (P-2)	Wiring for light point / fan point / exhaust fan point / call bell point with 1.5 sq.mm FR PVC insulated copper conductor single core cable in surface medium class PVC conduit, with piano type switch, phenolic laminated sheet ,suitable MS box and earthing the point with 1.5 sq. mm.FR PVC insulated copper conductor single core cable etc as required.				
1.1	1.8.3	Group C	21	Point		
2	CPWD DSR (Elect.) -2012, Code-1.12 (P-3)	Wiring for light/ power plug with 2X4 sq. mm FR PVC insulated copper conductor single core cable in surface/ recessed medium class PVC conduit along with 1 No 4 sq. mm FR PVC insulated copper conductor single core cable for loop earthing as required.	60	Metre		

3	CPWD DSR (Elect.) -2012, Code-1.14 (P-3)	Wiring for circuit / submain wiring along with earth wire with the following sizes of FR PVC insulated copper conductor, single core cable in surface / recessed medium class PVC conduit as required.				
3.1	1.14.2	2 X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire.	60	Metre		
3.2	1.14.5	2x10 sq.mm+1x10 sq. mm	17	Metre		
4	CPWD DSR (Elect.) -2012, Code-1.22 (P-6)	Supplying and fixing following sizes (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in front including painting etc. as required. Switches in recess etc. as required.				
4.1	1.22.1	75mmx75mmx60mm deep	4	Each		
5	CPWD DSR (Elect.) -2012, Code-1.23 (P-6)	Supplying and fixing following piano type switch/ socket on the existing switch box /cover including connection etc.as required.				
5.1	1.23.1	5/6 Amp switch	7	Each		
5.2	1.23.4	3 pin 5/6 Amp socket outlet	7	Each		
5.3	1.23.3	15/16 Amp switch	4	Each		
5.4	1.23.5	6 Pin 15/16 amps socket outlet	4	Each		
6	CPWD SOR (Elect.) -2012, Code-2.10 (P-13)	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.				
7	2.10.1	Single pole (20 A - 4 No. + 10 A - 4No.)	8	Each		
8	ARC 2014-15	Electronic regulator for fan ( heavy duty socket type) 100 watt,240 V	4	No.		

9	CPWD SOR (Elect.) -2012, Code-2.16 (P-10)	Supplying and fixing DP Sheet steel enclosure on surface /recess along with 32 amps 240 Volts "C" curve DP MCB complete with connections testing and commissioning etc. as required.	1	Nos.		
10	CPWD-DSR (Elect.)-2012, Code - 2.14 (Page - 13)	Supplying and fixing following rating, double pole, (single phase and neutral), 240 volts, residual current circuit breaker (RCCB), having a sensitivity current upto 300 milli amperes in the existing MCB DB complete with connections, testing and commissioning etc. as required.				
10.1	2.14.1	25 amps	1	Each		
11	Ref.- CPWD,DSR (Elect.-2012), 2.3, page -10	Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 volts on surface /recess, complete with tinned bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required.(But without MCB/RCCB/Isolater)				
11.1	2.3.7	2+8way,Double door	1	Each		
12	CPWD-SOR (Elect.)-2012, Code - 1.18 (Page - 5)	Supplying and drawing following pair 0.5 sq mm FR PVC insulated annealed copper conductor, unarmored telephone cable in the existing surface/ recessed steel/ PVC conduit as required.				
12.1	1.18.2	2 Pair	10	Each		
13	CPWD-DSR (Elect.)-2012, Code - 1.19 (Page - 5)	Supplying and drawing co-axial TV cable RG-6 grade, 0.7 mm solid copper conductor PE insulated, shielded with fine tinned copper braid and protected with PVC sheath in the existing surface/ recessed steel/ PVC conduit as required.	10	Each		

14	CPWD-DSR (Elect.)-2012, Code - 1.1.23 (Page -6)	Supplying and fixing following Piano type switch/socket on the existing switch box/cover including connection etc. as required.				
14.1	1.23.6	Telephone Socket outlet	1	Each		
14.2	1.23.7	T.V. Socket outlet	1	Each		
Total "B"						Rs.:
<b>"C" Rewiring &amp; modification of power supply arrangement of Qr. No. 7/A ( C-Type )</b>						
S/N	Reference	Description	Qty.	Unit	Unit Cost (₹)	Total Cost (₹)
1	CPWD DSR (Elect.) -2012, Code-1.8 (P-2)	Wiring for light point / fan point / exhaust fan point / call bell point with 1.5 sq.mm FR PVC insulated copper conductor single core cable in surface medium class PVC conduit, with piano type switch, phenolic laminated sheet ,suitable MS box and earthing the point with 1.5 sq. mm.FR PVC insulated copper conductor single core cable etc. as required.				
1.1	1.8.3	Group C	20	Point		
2	CPWD DSR (Elect.) -2012, Code-1.12 (P-3)	Wiring for light/ power plug with 2X4 sq. mm FR PVC insulated copper conductor single core cable in surface/ recessed medium class PVC conduit along with 1 No 4 sq. mm FR PVC insulated copper conductor single core cable for loop earthing as required.	60	Metre		
3	CPWD DSR (Elect.) -2012, Code-1.14 (P-3)	Wiring for circuit /submain wiring along with earth wire with the following sizes of FR PVC insulated copper conductor, single core cable in surface / recessed medium class PVC conduit as required.				
3.1	1.14.2	2 X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire.	60	Metre		

4	CPWD DSR (Elect.) -2012, Code-1.22 (P-6)	Supplying and fixing following sizes (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in front including painting etc. as required. Switches in recess etc. as required.				
4.1	1.22.1	75mmx75mmx60mm deep	4	Each		
5	CPWD DSR (Elect.) -2012, Code-1.23 (P-6)	Supplying and fixing following piano type switch/ socket on the existing switch box /cover including connection etc. as required.				
5.1	1.23.1	5/6 Amp switch	8	Each		
5.2	1.23.4	3 pin 5/6 Amp socket outlet	8	Each		
5.3	1.23.3	15/16 Amp switch	4	Each		
5.4	1.23.5	6 Pin 15/16 amps socket outlet	4	Each		
6	CPWD SOR (Elect.) -2012, Code-2.10 (P-13)	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.				
7	2.10.1	Single pole (20 A - 4 No. + 10 A - 4No.)	8	Each		
8	ARC 2014-15	Electronic regulator for fan (heavy duty socket type) 100 watt, 240 V	4	No.		
9	CPWD SOR (Elect.) -2012, Code-2.16 (P-10)	Supplying and fixing DP Sheet steel enclosure on surface /recess along with 32 amps 240 Volts "C" curve DP MCB complete with connections testing and commissioning etc. as required.	1	Nos.		

10	CPWD SOR (Elect.) -2012, Code-2.3 (P-10)	Supplying and fixing following way, single pole and neutral, sheet steel, MCB Distribution board, 240V, on surface recess, complete with tinned copper bus bar, din bar inter connections, powdered painted including earthing etc. as required. (But without MCB/RCCB/Isolator)				
10.1	2.3.7	2+8way,Double door	1	Each		
11	CPWD-DSR (Elect.)-2012, Code - 2.14 (Page - 13)	Supplying and fixing following rating, double pole, (single phase and neutral), 240 volts, residual current circuit breaker (RCCB), having a sensitivity current upto 300 milli amperes in the existing MCB DB complete with connections, testing and commissioning etc. as required.				
11.1	2.14.1	25 amps	1	Each		
12	CPWD-SOR (Elect.)-2012, Code - 1.18 (Page - 5)	Supplying and drawing following pair 0.5 sq mm FR PVC insulated annealed copper conductor, unarmored telephone cable in the existing surface/ recessed steel/ PVC conduit as required.				
12.1	1.18.2	2 Pair	10	Each		
13	CPWD-DSR (Elect.)-2012, Code - 1.19 (Page - 5)	Supplying and drawing co-axial TV cable RG-6 grade, 0.7 mm solid copper conductor PE insulated, shielded with fine tinned copper braid and protected with PVC sheath in the existing surface/ recessed steel/ PVC conduit as required.	10	Each		
14	CPWD-DSR (Elect.)-2012, Code - 1.1.23 (Page -6)	Supplying and fixing following Piano type switch/socket on the existing switch box/cover including connection etc. as required.				
14.1	1.23.6	Telephone Socket outlet	1	Each		
14.2	1.23.7	T.V. Socket outlet	1	Each		
Total "C"					Rs.:	
Total ( A+B+C)					Rs.:	

**(Inclusive All Taxes)**

**(Rupees.....only)**

**ANNEXURE – II****PROFORMA OF BANK GUARANTEE IN LIEU OF PART BID****SECURITY / EARNEST MONEY DEPOSIT**

To,  
 M/s. Central Mine Planning & Design Institute Limited,  
 Regional Institute - I  
 G. T. Road (West End), Asansol  
 Dist: Burdwan, PIN – 713 304

Dear Sirs,

1. In consideration of “Central Mine Planning & Design Institute Limited, Regional Institute - I” having its Registered Office at Asansol (hereinafter called “the Company” which expression shall unless repugnant to the subject or context includes its successors and assigns) having agreed under the terms and conditions contained in ..... for the work “.....” issued in favour of M/s..... for (hereinafter referred to as “the Bid” to accept the Deed of guarantee as herein provided for Rs..... from the Schedule/Nationalised Bank in lieu of Bids/Earnest Money deposit to be made by M/s.....(hereinafter called “the tenderer ” ) or in lieu of Demand draft of equal amount, for the due fulfillment of the terms and conditions contained in the said Bid documents by the Tenderer, we the.....Bank .....(hereinafter referred to as the said Bank) having its Registered Office at ..... do hereby undertake and agreed to pay the company to the extent of Rs..... on demand stating that the amount claimed by the company is due and payable by the Tenderer for the reasons of failure/negligence in performing the terms and conditions contained in the contract /Bid by the buyer and to unconditionally pay the amount claimed by the company on demand without any demur to the extent aforesaid.
3. We..... Bank agree that the company shall be the sole judge as to whether the said Tenderer has failed/neglected in performing any of the terms and conditions of the said contract/Bid and the decision of the company in this behalf shall be final and binding on us.
4. We the said Bank further agree that the Guarantee herein contained shall remain in full force and effect upto 365 (three hundred sixty five) days on and from..... and any claim received after the said date shall in no case bind the Bank.
5. The Company shall have the fullest liberty without affecting in any way the liability of the Bank under this guarantee or indemnity from time to time vary any of the terms and conditions of the said Bid document or to extend the time of performance by the said Tenderer or to postpone any time and from time to time any of the powers exercisable by it against the said Tenderer and either to enforce or to forbear from enforcing any of the terms and conditions governing the said Bid document or

securities available to the company and the said Bank shall not be released from its liability under these presents.

6. Notwithstanding anything contained herein the liability of the said Bank under this guarantee is restricted to Rs.....and this Guarantee shall come into force from the date hereof and shall remain in full force and effect till 365 (three hundred sixty five) days on and from ..... unless the written demand or claim under this guarantee is made by the Company with us on or before expiry of 365 (three hundred sixty five) days on and from .....all rights of the company under this guarantee shall cease to have any effect and we shall be relieved and discharged from our liabilities hereunder.
6. We the said Bank lastly undertake not to revoke this guarantee during its currency except with the previous consent of the company in writing and agree that any change in the constitution of the said Tenderer or the said Bank shall not discharge our liability hereunder.
7. This guarantee issued by Sri.....who is authorized by the Bank.
8. **All disputes are subject to Asansol Court Jurisdiction Only.**