



Ref. No: CMPDIL/RI-1/E&M/2024/04

Date: 03.04.2024

NOTICE INVITING QUOTATIONS

Sealed quotations are invited from Enlisted / Reputed / Working contractors for Rewiring & modification of 1 No. "C" type quarter as per **Technical Specification & SCHEDULE OF REQUIREMENT (ANNEXURE-I)** and **TERMS & CONDITIONS** given below:-

- a) Date of Availability of Quotation : 03-Apr-24 (from 10.30 AM)
- b) Last date of Availability of Quotation : 17-Apr-24 upto 12.00 Noon.
- c) Last date & time for submission of offer : 18-Apr-24 upto 03:00 PM.
- d) Due date & time of opening of Offers : 18-Apr-24 at 03.30 PM

Note :

1. ***IF THE QUOTATION IS NOT OPENED ON THE ABOVE DATE, DUE TO UNFORESEEN CIRCUMSTANCES, THEN IT WILL BE OPENED ON THE NEXT WORKING DATE.***
2. ***BIDDER OR THEIR AUTHORIZED REPRESENTATIVES MAY ATTEND THE OPENING OF THE QUOTATION. AUTHORISED REPRESENTATIVE MUST PRODUCE A POWER OF ATTORNEY IN HIS FAVOUR***

Quotation can be obtained from the office of **HOD (E&M)/Systems**, CMPDI, RI-1, Asansol during **10.30 AM to 12.00 Noon** on all working days from **03-Apr-24 to 17-Apr-24** upto **12.00 Noon**, free of cost. Quotation can also be downloaded from CMPDI website www.cmpdi.co.in during the period from **03-Apr-24 to 17-Apr-24**

TERMS & CONDITIONS:

1. MODE & METHOD OF SUBMISSION OF QUOTATION

Quotation must be submitted in a sealed cover super-scribing "Rewiring & modification of 1 No. "C" type quarter", "Quotation Number, Date & Time of Opening" and should be dropped in the nominated 'TENDER BOX' kept in the office of the **HOD (E&M) / SYSTEMS**, CMPDI, RI-1, Asansol. Envelopes Stapled shall not be accepted.

2. Sealed quotation shall be opened on **18-Apr-24 at 03.30 PM** in presence of the bidders or their authorised representatives. Authorized Representative must produce power of attorney in his favour.
3. The offer shall be accompanied with the copies of :-
 - a) Valid Trade license
 - b) GST Registration Certificate
 - c) PAN No.
 - d) Electrical workman permit
4. Bidders should quote the price on **FOR DESTINATION** basis, for delivery to CONSIGNEE/CONSIGNEES END. The offer should indicate, rate per unit and total price **inclusive of all applicable taxes, duties, installation testing & commissioning charges and incidental charges, if any.**
5. The price should be quoted as per the appended format at **Annexure - I**.
6. No Deviation from the terms and conditions of the NIQ shall be accepted, Conditional bid shall be outright rejected.

7. NOTE

- a. **ALL PAGES OF THE OFFER ALONG WITH THE ENCLOSURES ARE TO BE SUBMITTED DULY SIGNED AND STAMPED.**
- b. **OFFERS ERASED, CUTTING AND OVER WRITTEN WILL BE SUMMARILY REJECTED UNLESS CORRECTION IS AUTHENTICATED WITH THE BIDDER'S SIGNATURE.**
8. Offers received after the submission time of the due date of the tender shall not be accepted.

9. CONSIGNEE

The Regional Director, CMPDI, RI-1, Asansol – 713 304.

10. **GST: CMPDIL, RI-1, Asansol have GSTIN No.-19AAACC7475N1Z1 having address - CMPDI LTD, REGIONAL INSTITUTE-I, G.T ROAD (WEST), ASANSOL- 713304 (West Bengal).**

11. PAYING AUTHORITY

HOD (F) or his authorized representative.

12. PAYMENT TERM

100% of the billed amount will be paid after satisfactory completion of work. **The payment shall be made by e-payment (RTGS/NEFT). Bidders are advised to submit bank detail along with the pre-receipted bill** duplicate along with Warranty Certificate are to be submitted to **HOD (E&M) / SYSTEMS,**

13. COMPLETION

The job should be completed within 20 days from the date of issue of work order.

14. WARRANTY

You have to provide 1 (One) Year Warranty w. e. f. date of installation/commissioning. Bidders must indicate the Manufacturer's guarantee for the offered item. Only genuine spares will be accepted.

15. PENALTY

A sum not exceeding 0.5% per week of the job value which have not been completed for each week or part of the week during the execution of the work subject to maximum of 10% of work value will be recovered from the bill of the party unless subsequent extension of time of completion of work is granted by the Company in writing.

16. **CMPDI, RI-1 reserves the right to accept or reject partly / fully or split-up any or all offers without assigning any reason thereof. No dispute of any kind can be raised against this right of the buyer in any court of law or elsewhere. No correspondence will be entertained in this regard.**

17. **All disputes are subject to Asansol Court Jurisdiction Only.**

This issue with the approval of competent authority.

W/3.04.2024
HOD (E&M)

Copy To:

1. RD, RI-1, Asansol
2. HOD(P&A) for display in notice board
3. HOD (Fin.), RI-1, Asansol
4. Office Copy.

Ch 31/12/24

S/N	Description	Qty.	Unit	Basic unit rate (Rs.)	Total Cost exclusive GST (Rs.)
1	Wiring for light point / fan point / exhaust fan point / call bell point with 1.5 sq. mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq. mm. FRLS PVC insulated copper conductor single core cable etc as required. Make: Polycab, Mescab, Finolex & Havells (wire) and Crabtree, Anchor & Finolex (switch & socket) or equivalent (As per IS)				
1.1	Group A	20	Point		
2	Wiring for light / power plug with 2X4 sq. mm. FRLS PVC insulated copper conductor single core cable in surface/ recessed medium class PVC conduit along 1 No. 4 sq. mm. FRLS PVC insulated copper conductor single core cable for loop earthing as required. Make: Havelles, Finolex & Polycab, Finolex or equivalent (As per IS).	65	Metre		
3	Wiring for circuit / submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface / recessed medium class PVC conduit as required. Make: Havelles, Finolex & Polycab or equivalent (As per IS)				
3.1	2 X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire.	60	Metre		
4	Supply & fixing of (SP) 5/6 amps, one way modular switch, ISI marked. Make: Standard, Finolex & Anchor or equivalent.	8	Each		
5	Supply & fixing of SP, 3 pin 5/6 amps modular socket outlet, ISI marked. Make: Standard, Finolex & Anchor or equivalent.	8	Each		
6	Supply & fixing of SP, 15/16 amps, one way modular switch, ISI marked. Make: Standard, Finolex & Anchor or equivalent.	6	Each		
7	Supply & fixing of SP, 6 pin 15/16 amps modular socket outlet, ISI marked. Make: Standard, Finolex & Anchor or equivalent.	6	Each		
8	Supply and fixing of following size/modules, GI box along with modular base & cover plate for modular switches in recess etc as required. Make: Standard, Finolex & Anchor or equivalent.				
8.1	1 or 2 Module (75mmX75mm)	5	Each		
8.2	3 Module (100mmx75mm)	10	Each		

9	Supply and fixing of 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required. Make: L&T, Standard, Finolex & Anchor or equivalent.				
9.1	Single pole (20 A - 5 No. + 10 A - 3 No.)	8	Each		
10	Supply and fixing of stepped type electronics fan regulator on the existing modular plate switch box including connection but excluding modular plate etc. as required. Make : Standard, Finolex & Anchor or equivalent	4	No.		
11	Supply & fixing telephone Socket outlet, Modular type ISI marked. Make: Standard, Finolex & Anchor or equivalent.	1	Each		
12	Supply and drawing of following pair 0.5 sq mm FRLS PVC insulated annealed copper conductor, unarmored telephone cable in the existing surface/ recessed steel/ PVC conduit as required. Make: Finolex, Havells, polycab or equivalent.				
12.1	2 Pair	10	Meter		
13	Supply and drawing of co-axial TV cable RG-6 grade, 0.7 mm solid copper conductor PE insulated, shielded with fine tinned copper braid and protected with PVC sheath in the existing surface/ recessed steel/ PVC conduit as required. Make: Finolex, Havells, polycab or equivalent.	5	Meter		
14	Supply & fixing of T.V. Socket outlet modular type, Make : Standard, Finolex & Anchor or equivalent	1	Each		
15	Supply and fixing of following way, single pole and neutral, steel sheet MCB distribution board, 240 volts on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar interconnections, powder painted including earthing etc. as required. (But without mcb/rccb/islator) Make: Standard, Anchor, JJ, Havells or equivalent				
15.1	2+10way, Single door	1	Each		
16	Dismantling Of old wiring Complete and shifting of old material at a suitable place as per direction of Engineer incharge.	1	Job		
17	Supply & fixing of 'C' series MCB,DP (In accordance with IS/IEC 60898-1) 240 V,50 Hz,10 KA, Rating 40 A. Make: L&T, Standard, Anchor or equivalent (As per IS)	1	Each		
Total					Rs.:
GST @.....%					Rs.:
Total Amount(Inclusive GST)					Rs.: